

**Government of Bihar
Public Health Engineering Department
Water Quality Report**

District:Katihar

Water sample are given by- Sri Swami Ramanamananda

Water sample Receiving Date-12-05-2023 in Lab.

SL. NO	Pan chay at	Name of the village.	Villag e Code.	Populat ion (2001)	Name of the Habitati on.	Nea rest Pers on.	NTU		Test Result (in ppm)											
							Turbidity	P.H	Conductivity	Total Hardness	Total Alkalinity	Chloride	Iron	Calcium	Magnesium	Nitrate	T.D.S.	As	F	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
1	Ramakrishna Mission Vidyamandir Higher Secondary School (10+2) P.O & Dist. - Katihar, Bihar (854105)						1	7.13	125	80	100	10	0.34	32	11	-	81	BDL	-	
BIS: 10500:2012 (Second revision)	Desirable limit						1	6.5- 8.5	-	200	150	250.0	1.00	75	30	45.00	500	0.01	1	
	Permissible limit in absence of alternate source						5	NR	-	600	400	1000.0	NR	200	100	NR	2000.0	NR	1.5	

Aparna Keshri
Signature of Lab.
Assistant
15-05-2023

S. K. Singh
Signature of Chemist
15-05-2023

A. S. Singh
15/05/23
Assistant Engineer
P.H.Sub-Div.Katihar

V. K. Singh
15/5
Executive Engineer
P.H.Div.Katihar